

1301:7-9-01 APPLICABILITY.

(A) This rule is adopted by the fire marshal in accordance with Chapter 119. Of the Revised Code and shall not be considered a part of the "Ohio Fire Code."

(B) Notwithstanding paragraphs (A)(7) to (A)(11) of rule 1301:7-9-06 of the Administrative Code and paragraphs (A)(7) to (A)(11) of rule 1301:7-9-08 of the Administrative Code, no owner or operator shall install an UST system listed in paragraphs (A)(7) to (A)(11) of rule 1301:7-9-06 of the Administrative Code for the purpose of storing a regulated substance unless the UST system complies with all of the following:

(1) the UST system is installed and constructed in such a manner so as to prevent releases of the regulated substance due to corrosion or structural failure for the operational life of the UST system;

(2) the UST system is cathodically protected against corrosion, constructed of noncorrodible material, steel clad with a noncorrodible material, or designed in a manner to prevent a release or threatened release of any stored substance; and

(3) is constructed or lined with material that is compatible with the stored substance.

(C) Notwithstanding paragraphs (B) to (B)(3) of this rule, an UST system listed in paragraphs (A)(7) to (A)(11) of rule 1301:7-9-06 of the Administrative Code may be installed, for the purpose of storing regulated substance, without corrosion protection at a site that is determined by a corrosion expert not to be corrosive enough to cause it to have a release due to corrosion during its operating life. Owners and operators shall obtain written permission from the bureau chief to install such a system prior to installation and shall maintain records that demonstrate compliance with the requirements of this paragraph for the remaining life of the UST system.

Effective: January 22, 1993

Promulgated under: 119.03

Authorized by: 3737.88 to 3737.882

Amplifies: 3737.88 to 3737.882

Prior Effective Date: 11/5/90

Printed: 1/22/93