Ohio Department of Commerce
Division of Industrial Compliance
John R. Kasich, Governor
Jacqueline T. Williams, Director

Monthly Fire Service Log

ASME A17.1 -2016 8.6.11.1 Maintenance of Firefighter's Service. All elevators provided with firefighter's service shall be subjected to monthly Phase I recall, and a minimum of one-floor operation on Phase II to assure the system is operative. A written record of findings on the operation shall be maintained and kept on the premises. Deficiencies shall be corrected.

State ID #: _____ Location Name: _____

Date:	Phase I	Phase II	Checked By: (Signature)	Passed	Failed

Comments:_____

_____

_____

_____

Bureau of Operations & Maintenance - Elevators
6606 Tussing Road
Reynoldsburg, OH 43068-9009
Rev. 5/2018

An Equal Opportunity Employer and Service Provider

614-644-3524
Fax 614 -644-5200
TTY/TDD 800-750-0750
com.ohio.gov
DIC 4611; DIC-18-0012