

**\*\*\*DRAFT - NOT FOR FILING\*\*\***

**4101:5-1-03**      **Enforcement.**

(A) The superintendent of the division of industrial compliance shall enforce all provisions of rules 4101:5-1-01 to 4101:5-3-02 and rules 1301:3-6-01 to 1301:3-6-06 of the Administrative Code relating to the design, construction, repair, alteration, and maintenance of elevators and elevator controls as defined in rule 4101:5-1-02 of the Administrative Code.

Exception: Municipal corporations, such as the city of Cleveland and the city of Cincinnati, which are authorized to adopt regulations for the regular inspection of elevators pursuant to section 4105.19 of the Revised Code.

(B) All requirements within the standards referenced in "Table 4101:5-3-01" of rule 4101:5-3-01 of the Administrative Code that relate to the construction of the building and the building service equipment located within an elevator hoistway enclosure, hoistway, machine room, and control room such as, but not limited to, requirements for wall materials, wall fire resistance ratings, fire and/or smoke dampers, means of egress doors and hardware, ladders, air conditioning systems, ventilation systems, fire protection systems, lighting systems, electrical power supply to the elevator controls, lighting switches, electrical disconnects and selective coordination of overcurrent protective devices (OCPD), plumbing, sanitary piping, and sump pits shall be enforced by the building official having jurisdiction as determined in division (A)(1) of section 3791.04 of the Revised Code.