

*****DRAFT - NOT FOR FILING*****

1301:3-5-03 Inspection reports.

(A) All inspection reports shall be submitted to the superintendent within thirty days of the date of inspection.

(B) Inspections shall be reported on forms supplied by the superintendent or as follows:

- (1) The ~~ASME National Board Form NB-5, "Boiler or Pressure Vessel Data Report – First Internal Inspection," long form, boiler data report – first internal inspection~~ shall be used when reporting:
 - (a) The initial internal inspection following the installation of the boiler;
 - (b) The first inspection after location or ownership of the boiler has changed; or
 - (c) A major repair. The report of an inspection made following a major repair shall include a description of the repair with necessary sketches.
- (2) The ~~ASME short form, boiler internal reinspection report~~ National Board Form NB-6, "Boiler-Fired Pressure Vessel – Report of Inspection," shall be used when reporting all inspections of boilers required to be inspected periodically where a renewal of the certificate of operation is required.